



- LEGEND**
1. Access floor panel
 2. Vinyl gasket for non fastened panels
 3. 2mm thick die formed galv. steel head
 4. Steel stud 3/4" - 10 UNC
 5. 38mm galv. steel coupling nut
 6. 2mm thick die formed embossed galv. steel base

PEDESTAL SPECIFICATIONS

Pedestal Assembly

- Assembly for 100mm FFH shall provide a 2721 kg axial load without permanent deformation.
- Assembly shall provide ± 9 mm total adjustment with a minimum finished floor height of 90mm.

Pedestal Head

- 2mm thick die formed hot dipped galvanized steel pedestal head projection welded to threaded rod
- Electro galvanized solid steel stud shall be 3/4" - 10 UNC and projection welded to base plate.
- Pedestal head shall have tapped holes for engagement of posilock screws and shall incorporate alignment guides and locating points to laterally contain and positively position the floor panel with or without the use of screws.

Pedestal Base

- Base to be at least 100 mm square and hot dipped galvanized steel.
- 38mm electro galvanized coupling nut shall be 3/4" - 10 UNC and projection welded to base.

Perimeter

- Perimeter pedestal shall provide support for panels around columns and walls.
- Base to be at least 100 cm square and hot dipped galvanized steel.
- 28mm electro galvanized coupling nut shall be 3/4" - 10 UNC and projection welded to base.

